## nigLon Control & Automation

## ENCLOSED SWITCHGEAR

## STAINLESS STEEL 4 POLE DISCONNECTOR SS12504P



1250A 4 pole switch disconnector in a metal enclosure to IP66. Enclosure has separate lock and reversible door. The switch handle is padlockable and defeatable. All terminals are provided with shrouds. Earth studs are fitted and fixing brackets and earth straps are included

#### **General Characteristics**

Standards	EN60947-1 ,EN60947-3	
Rated Operational Voltage (Ue)	415 V	
Rated Operational Frequency	50/60 Hz	
Rated Operational Current AC-22 A	1250A	
Rated Operational Power (1) AC-23 @ 415V	400kW	
Rated Breaking Capacity AC-23 @ 415V	8000A	
Rated Short Time Withstand Current (Icw) @ 690V 1s	24kA	
Mechanical Endurance (2)	6000 ops	
Electrical Endurance @ 0.65pf	500 ops	
Defeatable Handle	Accepts 3 Padlocks	
Weight	29.7 Kg	
Terminal Bolt Size	M12 x 60	
Terminal Tightening Torque	5075 Nm	
Operating Torque	21Nm	
(1) The kW ratings are accurate for three phase 1500 rpm standard asynchronous motors (2) In single phase test to IEC629 (3) Divided by 2 for operational cycle		


#### **Enclosure Characteristics**


Standard	EN61439-1
Overall Dimensions HxWxD	1000x800x300mm
Degree of Ingress When Fitted	IP65
Construction	304 stainless steel
Finish	Brushed stainless

#### **Available Accessories**

1NO/1NC Auxilliary Contact	800AUX1/1
2NO/2NC Auxilliary Contact	800AUX2/2
Document Pocket	A4DOCW
Stainless Steel Bit Lock	SSBL
Spare T Bit Key	STBK
Mild steel Padlockable Lock	DBPL

#### **Technical Drawing**





#### **Additional Information**


This product is for use by skilled persons or instructed persons. The installation of this product must comply with current IEE regulations. The IP rating of the unit can be compromised if the correct use of glands is not followed. Terminals, including those factory fitted, must be checked for correct tightness before commissioning. All terminals should be periodically checked for correct tightness. The data herein serves only to describe the product and should not be regarded as representing guaranteed properties in the legal sense. We reserve the rights of modification whilst every care has been take in ensuring the accuracy of this catalogue, the Supplier accepts no liability whatsoever for any eventuality arising from errors or omissions within its catalogues, brochures or within any online presence.

### nigLon Control & Automation

# ENCLOSED SWITCHGEAR

# STAINLESS STEEL 4 POLE DISCONNECTOR SS12504P

#### **Wiring Diagram**



#### Additional Information

This product is for use by skilled persons or instructed persons. The installation of this product must comply with current IEE regulations. The IP rating of the unit can be compromised if the correct use of glands is not followed. Terminals, including those factory fitted, must be checked for correct tightness before commissioning. All terminals should be periodically checked for correct tightness. The data herein serves only to describe the product and should not be regarded as representing guaranteed properties in the legal sense. We reserve the rights of modificationwhilst every care has been take in ensuring the accuracy of this catalogue, the Supplier accepts no liability whatsoever for any eventuality arising from errors or omissions within its catalogues, brochures or within any online presence.